

BUILDING SAFETY CERTIFICATE

No. AE-1/NB404/2024-25

Dated: 05/08/2024

Certified that the existing building GYAN STHALI ACADEMY at KATRA SHAMSHER KHAN, ETAWAH U.P. comprised of basement and GROUND FLOOR, FIRST FLOOR AND SECOND FLOOR owned/occupied by GYAN STHALI ACADEMY have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of UP PWD on 28/06/2024 in the presence of Mr. Shiv Prashad Yadav, Gyan Sthali Residential School, Karwa Khera, Etawah. U.P. and that the building/premises is fit for occupancy upto classes PG to XII (X/XII) with effect from 28/06/2024. For a period of 3 years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Two doors in every class room with a size of wide 1.60 m & height 2.60 m minimum.
2. Fire Safety System working properly.
3. Minimum height of first floor terrace is 3.60 meter.
4. Teacher give training for students about fire protection.

Issued on 05/08/2024 at by.

Signature with Seal :

05/08/24
सहायक अभियन्ता
निर्माण खण्ड-1
लोक निर्माण विभाग-इटावा

Name : Gaurav Jain

Designation : Assistant Engineer

Name & Address of Department/Office : U.P. PWD